

ABB Drives

User's Manual Ethernet Adapter Module RETA-02



Ethernet Adapter Module RETA-02

User's Manual

3AFE68895383 Rev A
EN
EFFECTIVE: 16.07.2007

Safety instructions

Overview

This chapter states the general safety instructions that must be followed when installing and operating the RETA-02 Ethernet Adapter module.

The material in this chapter must be studied before attempting any work on, or with, the unit.

In addition to the safety instructions given below, read the complete safety instructions of the specific drive you are working on.

General safety instructions



WARNING! All electrical installation and maintenance work on the drive should be carried out by qualified electricians. The drive and adjoining equipment must be properly earthed.

Do not attempt any work on a powered drive. After switching off the mains, always allow the intermediate circuit capacitors to discharge for 5 minutes before working on the frequency converter, the motor or the motor cable. It is good practice to check (with a voltage indicating instrument) that the drive is in fact discharged before beginning work.

The motor cable terminals of the drive are at a dangerously high voltage when mains power is applied, regardless of motor operation.

There can be dangerous voltages inside the drive from external control circuits even when the drive mains power is shut off. Exercise appropriate care when working on the unit. Neglecting these instructions can cause physical injury or death.

Table of contents

Safety instructions

Overview	5
General safety instructions	5

Table of contents

Introduction

Intended audience	11
Before you start	11
What this manual contains	11
Terms used in this manual	12
Product and service inquiries	13
Product training	13
Providing feedback on ABB Drives manuals	13

Overview

Overview	15
Modbus/TCP	15
PROFINET IO	15
The RETA-02 Ethernet Adapter module	16
Compatibility	17
Delivery check	17
Warranty and liability information	18

Quick start-up guide

Overview	19
Mechanical installation	19
Electrical installation	19
Drive configuration	19
Network configuration	20
Communication	21
Modbus/TCP configuration	21
PROFINET IO configuration	21

Mechanical installation

Mounting	29
----------------	----

Electrical installation

General cabling instructions	31
Ethernet connection	31

Drive configuration

Overview	33
RETA-02 configuration	33

Network configuration

Overview	43
IP settings configuration	44
PROFINET IO and DCP	47
Duplicate IP address detection	47

Master configuration

Overview	49
Configuring the system	49
System requirements	49

Communication profiles

Overview	51
Communication profiles	51
The PROFIdrive communication profile	52
The Control Word and the Status Word	52
References	52
Actual values	54
The ABB Drives communication profile	60
The Control Word and the Status Word	60
References	60
Actual values	62

Communication

Overview	69
Protocols	69
Modbus/TCP	70
Register read and write	70
Register mapping	70
PROFINET IO	73
Overview	73
Introduction to PROFINET IO	73
PROFINET IO in RETA-02	74
Cyclic messaging in Vendor mode	75
Cyclic messaging in PROFIdrive mode	76
Acyclic parameter access mechanism	76
Parameter data transfer examples	89

Identification and maintenance functions (I&M)	90
PROFIdrive profile-specific parameters	93
Diagnostic and alarm mechanism	97
Fault buffer mechanism	100
 <i>Diagnostics</i>	
LED indications	103
Led patterns	105
 <i>Definitions and abbreviations</i>	
PROFINET IO definitions	107
 <i>Technical data</i>	
RETA-02	109
Ethernet link	110

Introduction

Intended audience

The manual is intended for the people who are responsible for commissioning and using an RETA-02 Ethernet Adapter module. The reader is expected to have a basic knowledge of electrical fundamentals, electrical wiring practices and how to operate the drive.

Before you start

It is assumed that the drive is installed and ready to operate before starting the installation of the extension module.

In addition to conventional installation tools, have the drive manuals available during the installation as they contain important information not included in this manual. The drive manuals are referred to at various points of this document.

What this manual contains

This manual contains information on the wiring, configuration and use of the RETA-02 Ethernet Adapter module.

Safety instructions are featured in the first few pages of this manual.

Overview contains a short description of the Ethernet protocols and the RETA-02 Ethernet Adapter module, a delivery checklist, and information on the manufacturer's warranty.

Quick start-up guide contains a short description of how to set up the RETA-02 Ethernet Adapter module.

Mechanical installation contains placing and mounting instructions for the module.

Electrical installation contains wiring, bus termination and earthing instructions.

Drive configuration contains a description of bus configuration and activation of the communication

Network configuration explains the different methods of setting up the network configuration.

Master configuration explains the basic principle on how to configure the master system to communicate with the drive

Communication profiles describes the PROFIdrive drive profile and the ABB Drives profile

Communication contains a description of how data is transmitted through the RETA-02 module.

Diagnostics explains how to trace faults with the status LEDs on the RETA-02 module.

Definitions and abbreviations explains the definitions and abbreviations concerning the PROFINET IO product family

Technical data contains information on physical dimensions, configurable settings and connectors of the module and the specification of the Ethernet link.

Terms used in this manual

Communication Module

Communication Module is a name for a device (e.g. a fieldbus adapter) through which the drive is connected to an external communication network (e.g. a fieldbus). The communication with the module is activated with a drive parameter.

MAC ID

Every node on Ethernet network has to have a unique identifier. This node number is called MAC ID (Media Access Control ID).

Data Sets and Data Words

Each data set consists of three 16-bit words, i.e. data words. The Control (or Command) Word and the Status Word, References and Actual Values (see chapter *Communication*) are types of data words; the contents of some data words are user-definable.

RETA-02 Ethernet Adapter module

The RETA-02 Ethernet Adapter module is one of the optional fieldbus adapter modules available for ABB drives. The RETA-02 is a device through which a drive is connected to an Ethernet network.

Parameter

A parameter is an operating instruction for the drive. Parameters can be read and programmed with the drive control panel, or through the RETA-02 module.

Product and service inquiries

Address any inquiries about the product to your local ABB representative, quoting the type code and serial number of the unit in question. A listing of ABB sales, support and service contacts can be found by navigating to www.abb.com/drives and selecting *Drives – Sales, Support and Service network*.

Product training

For information on ABB product training, navigate to www.abb.com/drives and select *Drives – Training courses*.

Providing feedback on ABB Drives manuals

Your comments on our manuals are welcome. Go to www.abb.com/drives, then select successively *Drives – Document Library – Manuals feedback form*.

Overview

Overview

The RETA-02 Adapter module supports the Modbus/TCP and PROFINET IO network protocols. This chapter contains a short description of the above protocols and the RETA-02 Adapter module, a delivery checklist and warranty information.

Modbus/TCP

Modbus/TCP is a variant of the Modbus family of simple, vendor-neutral communication protocols intended for supervision and control of automation equipment. Specifically, it covers the use of Modbus messaging in an Ethernet environment using the TCP/IP protocols.

The implementation of the Modbus/TCP server in the RETA-02 module is done according to the Modbus/TCP Specification 1.0. The supported Modbus commands are listed in chapter [Communication](#).

The Modbus/TCP protocol allows the RETA-02 module to be used as an Ethernet bridge to control the drive. The RETA-02 module supports eight simultaneous IP connections.

Further information can be obtained from www.modbus.org.

PROFINET IO

PROFINET IO uses traditional Ethernet hardware and software to define a network that structures the task of exchanging data, alarms and diagnostics with Programmable Controllers and other automation controllers.

PROFINET IO can be thought as PROFIBUS on Ethernet. PROFINET IO uses two different communication channels to exchange data with programmable controllers and other devices. The standard TCP/IP channel is used for parameterization, configuration and acyclic read/write operations. The RT or Real

Time channel is used for standard cyclic data transfer and alarms. There is no theoretical limit for the amount of connected nodes in PROFINET IO network, but in practise, the programmable controllers and number of available network addresses limits the size.

The PROFINET IO protocol is specified in the IEC standards 61158 and 61784. The communication with a drive is specified in the PROFIdrive profile (v4) published by PROFIBUS INTERNATIONAL.

Further information can be obtained from www.profinet.com.

The RETA-02 Ethernet Adapter module

The RETA-02 Ethernet Adapter module is an optional device for ABB drives, which enables the connection of the drive to a Ethernet network. The drive is considered as a slave on the Ethernet network. Through the RETA-02 Ethernet Adapter module, it is possible to:

- give control commands to the drive (Start, Stop, Run enable, etc.)
- feed a motor speed or torque reference to the drive
- give a process actual value or a process reference to the PID controller of the drive
- read status information and actual values from the drive
- change drive parameter values
- reset a drive fault.

The Modbus/TCP and PROFINET commands and services supported by the RETA-02 Ethernet Adapter module are discussed in chapter [Communication](#). Please refer to the user documentation of the drive as to which commands are supported by the drive.

The adapter module is mounted into an option slot on the motor control board of the drive. See the *Hardware Manual* of the drive for module placement options.




Figure 1. The RETA-02 Adapter module.

Compatibility

The RETA-02 is compatible with all master stations that support the Modbus/TCP. PROFINET IO can be used with master stations that support PROFINET IO and sub-slots. Functionality of the RETA-02 is limited if master station doesn't support multiple sub-slots per slot.

Delivery check

The option package for the RETA-02 Ethernet Adapter module contains:

- Ethernet Adapter module, type RETA-02
- two screws (M3x10)
- this manual.

Warranty and liability information

The manufacturer warrants the equipment supplied against defects in design, materials and workmanship for a period of twelve (12) months after installation or twenty-four (24) months from date of manufacturing, whichever first occurs. The local ABB office or distributor may grant a warranty period different to the above and refer to local terms of liability as defined in the supply contract.

The manufacturer is not responsible for

- any costs resulting from a failure if the installation, commissioning, repair, alternation, or ambient conditions of the drive do not fulfil the requirements specified in the documentation delivered with the unit and other relevant documentation
- units subjected to misuse, negligence or accident
- units comprised of materials provided or designs stipulated by the purchaser.

In no event shall the manufacturer, its suppliers or subcontractors be liable for special, indirect, incidental or consequential damages, losses or penalties.

If you have any questions concerning your ABB drive, please contact the local distributor or ABB office. The technical data, information and specifications are valid at the time of printing. The manufacturer reserves the right to modifications without prior notice.

Quick start-up guide

Overview

This chapter presents the steps to take during the start-up of the RETA-02 Ethernet Adapter module. For more detailed information, see chapters [Mechanical installation](#), [Electrical installation](#), [Network configuration](#), [Master configuration](#) and [Communication](#) elsewhere in this manual.



WARNING! Follow the safety instructions given in this manual and the *Hardware Manual* of the drive.

Mechanical installation

- Insert the RETA-02 into its specified slot in the drive (SLOT2 for ACS550, SLOT1 for ACS800).
- Fasten the two screws.

Electrical installation

- Connect the Ethernet network cable (RJ-45 connector) to the RETA-02 module. Standard CAT 5 UTP or STP cables can be used. Avoid parallel runs with power (e.g. motor) cables.

Drive configuration

- Power up the drive. In Modbus/TCP mode the “MODULE STATUS” LED should be green. If the network cable is connected to an active network, the green “LINK/ACTIVITY” LED should also be lit or blinking. In PROFINET IO mode the “MODULE STATUS” led should be blinking red because the name of the device has not been assigned yet.
- The detailed procedure of activating the drive for communication with the module is dependent on the drive type. Normally, a parameter must be adjusted to activate the

communication. Refer to the *Firmware Manual* of the drive for information on the communication settings. With an ACS550 drive, set parameter 98.02 COMM PROT SEL to EXT FBA. With an ACS800, set parameter 98.02 COMM. MODULE LINK to FIELDBUS and parameter 98.07 COMM PROFILE to ABB DRIVES or GENERIC according to the selected communication protocol and profile.

Table 1. Possible protocol and profile combinations

Communication protocol	Communication profile	Drive profile
Modbus/TCP	ABB Drives profile	ABB Drives profile
PROFINET IO	Vendor profile	ABB Drives profile
PROFINET IO	PROFIdrive profile	Generic drive profile

- If the configuration is correct, parameter group 51 should appear in the parameter list of the drive and show the status of the RETA-02 configuration parameters.
- Select communication protocol with a configuration parameter 51.16 'PROTOCOL'
 - 0 = Modbus/TCP
 - 1 = PROFINET IO

Network configuration

To enable communication through the Ethernet network, the module needs a valid IP address. There are numerous ways of setting the module IP address; see chapter [Network configuration](#).

- One way to set the static IP address is to use the panel of the drive. Set IP address to bus configuration parameters 51.04 - 51.07, subnet mask to parameters 51.08 - 51.11 and gateway address to parameters 51.12 - 51.15 if necessary. Set bus configuration parameter 51.27 to REFRESH to enable the network settings.
- If PROFINET IO protocol is activated also device name is required to identify the drive. IO controllers and some configuration tools have a protocol called Discovery and

Configuration Protocol (DCP) for assigning the IP address and the device name. Also methods described in chapter [Network configuration](#) can be used to set the IP address of the module.

Communication

The module is now ready to operate with Modbus/TCP protocol according to Modbus/TCP specification 1.0 or PROFINET IO protocol. For more detailed information on modifying the protocol specific settings, see chapter [Drive configuration](#).

Modbus/TCP configuration

Modbus TCP is based on data registers, which hold IO and parameter values. See chapter [Communication](#) for register mapping and supported function codes.

PROFINET IO configuration

Install the RETA-02 GSDML file (e.g. GSDML-V2.0-ABBDrives-RETA02-yyyymmdd.xml, where yyyy = year, mm = month, dd = day of the month when the file was created) and after that update the device catalog.




Figure 2. Menu selection for installing the GSD file

RETA-02 Vendor and PROFIdrive objects should be available in the product catalog.




Figure 3. Product catalog

Example 1: PLC configuration in Vendor mode

PPO 6 consists of 10 input and output parameters. Eight of the inputs and outputs are freely configurable parameters. The first four of them can be mapped either with the bus configuration parameters or the initial record data of the PLC. The last four inputs and outputs can be mapped only with the initial record data of the PLC. In this example the bus configuration parameters are used to map the first four and initial record data the last four of the input and output parameters.

- Drag-and-drop the RETA-02 Vendor object from the device catalog to the PROFINET-IO-System. Also drag-and-drop the Vendor Object PPO 6 to slot one.




Figure 4. Adding RETA-02 Vendor object to configuration

- Right click the device object and open the *Object Properties* menu. Through this menu it is possible to change the device name in the hardware configuration.

Note: The DCP configuration tool, like Step7 must be connected to the Ethernet network to be able to set the name of the device.




Figure 5. RETA-02 object properties

- Assign device name.




Figure 6. Menu selection for assigning the device name

- Set *Bus Configuration* parameters as the source for the input and output parameters 1-4 through the *Properties* menu of the Vendor Object PPO6. Configure the last four inputs and outputs. If *Stop Action selection* is set to *Fail-safe values* configure them as well.




Figure 7. Properties menu of the Vendor Object PPO6

Table 2. ACS800 parameter settings with PPO 6

Drive parameter	Example setting for ACS800
10.01 EXT1 STRT/STP/DIR	COMM.CW
10.03 REF DIRECTION	REQUEST
11.03 EXT1 REF1 SELECT	COMM.REF
16.04 FAULT RESET SEL	COMM.CW
98.02 COMM. MODULE LINK	FIELDBUS
98.07 COMM PROFILE	ABB DRIVES
51.01 MODULE TYPE	PROFINET IO
51.02 COMM RATE	0 (Auto-negotiation)
51.03 DHCP	0 (Disabled)
51.04 - 51.07 IP ADDRESS	10.0.0.6
51.08 - 51.11 SUBNET MASK	255.255.255.0
51.12 - 51.15 GW ADDRESS	0.0.0.0
51.16 PROTOCOL	1 (PROFINET IO)
51.18 OUTPUT 1	4001 (Gain for PID)
51.19 OUTPUT 2	2202 (Accel time 1)
51.20 OUTPUT 3	2203 (Decel time 1)
51.21 OUTPUT 4	3401 (Process variable)
51.22 INPUT 1	103 (Frequency)
51.23 INPUT 2	104 (Current)
51.24 INPUT 3	106 (Power)
51.24 INPUT 4	107 (DC bus voltage)
51.26 In/out 1-4 src	2 Disabled (Source of the parameters selected on the PLC side)

Example 2: PROFIdrive profile with Std telegram 1 + 4 PZD

Standard telegram 1 is specified in the PROFIdrive specification 4.01. To include more inputs and outputs without changing the telegram structure different number of PZD's (process data) can be added. The notation used here is ABB specific. In this example, standard telegram 1 and four inputs and outputs are configured with the initial record data.

- After installing the GSD file drag-and-drop the RETA-02 PROFIdrive object to the PROFINET-IO-System. Also drag-and-drop the Std Tgm 1 + 4 PZD to the configuration.




Figure 8. Adding PROFIdrive object to configuration

- Right click the device object and open the *Object Properties* menu. Through this menu it is possible to change the device name in the hardware configuration.
- Assign device name.
- Set *Initial Record Data* as the source for the input and output parameters 1-4 through the *Properties* menu of the *Standard telegram 1*. If *Stop Action selection* is set to *Fail-safe values* configure them as well.




Figure 9. Properties menu of the Standard Telegram 1

- Mapping of the inputs and outputs has to be done through the *Properties* menu of the corresponding PZD. Input 1 could be for example 103 (Frequency).




Figure 10. Properties menu of a PZD

- After mapping the inputs and outputs they are visible also in the bus configuration parameters 18-24. The mapping cannot be

changed through the configuration parameters unless parameter 26 is set to 1 (Bus configuration parameters).

Table 3. ACS550 parameter settings with Std Telegram 1 + 4 PZD

Drive parameter	Example setting for ACS550
10.01 EXT1 COMMANDS	COMM
10.03 DIRECTION	REQUEST
11.03 REF1 SELECT	COMM
16.04 FAULT RESET SEL	COMM
98.02 COMM PROT SEL	EXT FBA
51.01 MODULE TYPE	PROFINET IO
51.02 COMM RATE	0 (Auto-negotiation)
51.03 DHCP	0 (Disabled)
51.04 - 51.07 IP ADDRESS	10.0.0.6
51.08 - 51.11 SUBNET MASK	255.255.255.0
51.12 - 51.15 GW ADDRESS	0.0.0.0
51.16 PROTOCOL	1 (PROFINET IO)
51.18 OUTPUT 1 (Read only)	4001 (Gain for PID)
51.19 OUTPUT 2 (Read only)	2202 (Accel time 1)
51.20 OUTPUT 3 (Read only)	2203 (Decel time 1)
51.21 OUTPUT 4 (Read only)	3401 (Process variable)
51.22 INPUT 1 (Read only)	103 (Frequency)
51.23 INPUT 2 (Read only)	104 (Current)
51.24 INPUT 3 (Read only)	106 (Power)
51.25 INPUT 4 (Read only)	107 (DC bus voltage)
51.26 In/out 1-4 src	2 Disabled (Source of the parameters selected on the PLC side)

Mechanical installation



WARNING! Follow the safety instructions given in this manual and in the *Hardware Manual*.

Mounting

The RETA-02 is to be inserted into its specific position in the drive. The module is held in place with plastic retaining clips and two screws. The screws also provide the earthing of the CAT 5 STP cable shield connected to the module, and interconnect the GND signals of the module and the control board of the drive.

On installation of the module, the signal and power connection to the drive is automatically made through a 34-pin connector.

Mounting procedure:

- Insert the module carefully into its position inside the drive until the retaining clips lock the module into position.
- Fasten the two screws (included) to the stand-offs.
- Set the IP address DIP switch of the module to the required position.

Note: Correct installation of the screws is essential for fulfilling the EMC requirements and for proper operation of the module.

Electrical installation



WARNING! Before installation, switch off the drive power supply. Wait five minutes to ensure that the capacitor bank of the drive is discharged. Switch off all dangerous voltages connected from external control circuits to the inputs and outputs of the drive.

General cabling instructions

Arrange the network cable as far away from the motor cables as possible. Avoid parallel runs. Use bushings at cable entries.

Ethernet connection

The network cable is connected to the RJ45 connector (X1) on the RETA-02 module. Standard CAT 5 UTP and CAT 5 STP (recommended) cables can be used. In case CAT 5 STP is used, the cable shield is connected via rc filter to drive frame through the module.

Drive configuration

Overview

This chapter gives information on configuring the RETA-02 Ethernet Adapter module and the drive.

RETA-02 configuration

After the RETA-02 Ethernet Adapter module has been mechanically and electrically installed according to the instructions in chapters [Mechanical installation](#) and [Electrical installation](#), the drive must be prepared for communication with the module.

ABB drives can receive control information from multiple sources including digital inputs, analogue inputs, the drive control panel and a communication module (e.g. RETA-02). ABB drives allow the user to separately determine the source for each type of control information (Start, Stop, Direction, Reference, Fault Reset, etc.). In order to give the fieldbus master station the most complete control over the drive, the communication module must be selected as source for this information. The detailed procedure of activating the drive for communication with the module is dependent on the drive type. Normally, a parameter must be adjusted to activate the communication. Please refer to the drive documentation.

As communication between the drive and the RETA-02 is established, several configuration parameters are copied to the drive. These parameters must be checked first and adjusted if necessary. The alternative selections for these parameters are discussed in more detail below the table.

Note: The new settings take effect only when the module is powered up the next time or when the module receives a 'Fieldbus Adapter parameter refresh' (Parameter 51.27) command from the drive.

Table 4. The RETA-02 configuration parameters

Par. no.	Parameter name	Alternative settings	Default setting
1	MODULE TYPE	(Read-only)	PROFINET IO
2	Comm rate	(0) Auto-negotiate; (1) 100 Mbit/s, full duplex; (2) 100 Mbit/s, half duplex; (3) 10 Mbit/s, full duplex; (4) 10 Mbit/s, half duplex	(0) Auto-negotiate
3	DHCP	(0) DHCP disabled; (1) DHCP enabled	(1) DHCP enabled
4	IP address 1	0...255	0
5	IP address 2	0...255	0
6	IP address 3	0...255	0
7	IP address 4	0...255	0
8	Subnet mask 1	0...255	0
9	Subnet mask 2	0...255	0
10	Subnet mask 3	0...255	0
11	Subnet mask 4	0...255	0
12	GW address 1	0...255	0
13	GW address 2	0...255	0
14	GW address 3	0...255	0
15	GW address 4	0...255 (0)	0
16	Protocol	(0) Modbus/TCP; (1) PROFINET IO	(0) Modbus/TCP
17	Modbus timeout	0...65535	0
18	Output 1	0...65535	0
19	Output 2	0...65535	0
20	Output 3	0...65535	0
21	Output 4	0...65535	0
22	Input 1	0...65535	0

23	Input 2	0...65535	0
24	Input 3	0...65535	0
25	Input 4	0...65535	0
26	In/Out 1-4 src	(0) Initial record data; (1) Bus configuration parameters; (2) Disable	2

1 MODULE TYPE

This parameter shows the module type as detected by the drive.
The value cannot be adjusted by the user.

If this parameter is undefined, the communication between the drive and the module has not been established.

2 Comm rate

Defines the baud rate for the Ethernet interface.

- 0 = Auto-negotiate
- 1 = 100 Mbit/s, full duplex
- 2 = 100 Mbit/s, half duplex
- 3 = 10 Mbit/s, full duplex
- 4 = 10 Mbit/s, half duplex

3 DHCP

The Dynamic Host Configuration Protocol (DHCP) is an Internet protocol for automating the configuration of computers that use TCP/IP. DHCP can be used to automatically assign IP addresses, to deliver TCP/IP stack configuration parameters such as the subnet mask and default router, and to provide other configuration information.

- 0 = DHCP disabled
- 1 = DHCP enabled

4 IP address 1

5 IP address 2

6 IP address 3

7 IP address 4

An IP address is assigned to each TCP/IP node on an Ethernet network. IP addresses consist of four decimal integers in the range of 0...255 separated by periods, each integer representing the value of one byte (8 bits, octet) in the IP address. These parameters define the four octets of the IP address.

Note: Setting any actuator of DIP switch S1 enables hardware address selection, in which case the IP address is of the format 192.168.0.xxx. The fourth octet is defined by the DIP switch. See chapter [Network configuration](#).

8 Subnet mask 1

9 Subnet mask 2

10 Subnet mask 3

11 Subnet mask 4

Subnet masks are used for splitting networks into subgroups, or subnets. A subnet mask is a binary pattern that is matched up with the IP address to turn part of the address field into a field for subnets. These parameters define the four octets of the subnet mask.

12 GW address 1

13 GW address 2

14 GW address 3

15 GW address 4

Gateways connect individual physical networks into a system of networks. When a node needs to communicate with a node on another network, the gateway transfers the data between the two networks. These parameters define the four octets of the gateway address.

16 Protocol

Selects the application protocol and communication profile for the network communication.

0 = Modbus/TCP

1 = PROFINET IO

17 Modbus timeout

The Modbus protocol does not have an implementation for timeout on application layer and this may be required when controlling a drive. A supervision method has been implemented for this purpose. If modbus timeout is set to zero, this feature is disabled. The unit of the parameter is 100 milliseconds (e.g. '22' will give a timeout of 2.2 seconds).

If the communication fault function is activated, Modbus timeout is the sum of communication fault time and the time defined here.

18 Output 1

19 Output 2

20 Output 3

21 Output 4

When Modbus/TCP protocol is in use, these parameters define the output (from master to drive) data words or drive parameters that are updated more frequently. Writing to and reading from the Modbus/TCP register corresponding to the parameter is faster.

When PROFINET IO protocol is in use, these parameters define the output (from master to drive) data words or drive parameters that can be used with the vendor specific PPO's or in addition to the Standard telegram 1 (see chapter [Communication](#)). Output words correspond to PZD's according to the table below.

Output	PZD
Output 1	PZD3
Output 2	PZD4
...	...
Output 8*	PZD10

*Outputs from 4 to 10 are defined separately in the PLC.

The contents are defined by a decimal number in the range of 0 to 65535 as follows:

0	Not used
1...99	Data set area of the drive
	1 Data set 1 word 1
	2 Data set 1 word 2
	3 Data set 1 word 3
	4 Data set 2 word 1
	5 Data set 2 word 2
	
	99 Data set 33 word 3
101...9999	Parameter area of the drive
	Format: (x)xyy, where (x)x = actual signal group or parameter group; yy = actual signal or parameter index. E.g. 103 = actual signal 01.03; 2202 = parameter 22.02.
10000...65535	Not supported by the drive

22 Input 1

23 Input 2

24 Input 3

25 Input 4

When Modbus/TCP protocol is in use, these parameters define the input (from drive to master) data words or drive parameters

that are updated more frequently. Reading from the Modbus/TCP register corresponding to the parameter is faster.

When PROFINET IO protocol is in use, these parameters define the input (from drive to master) data words or drive parameters that can be used with the vendor specific PPO's or in addition to the Standard telegram 1 (see chapter [Communication](#)). Input words correspond to PZD's according to the table below.

Input	PZD
Input 1	PZD3
Input 2	PZD4
...	...
Input 8*	PZD10

*Inputs from 4 to 10 are defined separately in the PLC.

The contents are defined by a decimal number in the range of 0 to 65535 as follows:

0	Not used
1...99	Data set area of the drive
	1 Data set 1 word 1
	2 Data set 1 word 2
	3 Data set 1 word 3
	4 Data set 2 word 1
	5 Data set 2 word 2
	
	99 Data set 33 word 3
101...9999	Parameter area of the drive
	Format: (x)xyy, where (x)x = actual signal group or parameter group; yy = actual signal or parameter index. E.g. 103 = actual signal 01.03; 2202 = parameter 22.02.
10000...65535	Not supported by the drive

26 In/Out 1-4 src

Selects the source for the first four inputs and outputs when PROFINET IO is used. User can map parameters to the first four inputs and outputs with the initial record data of the IO controller or by using the RETA-02 configuration parameters described above. Initial record data has a parameter that can be used to select the source in similar way.

- 0 = Initial record data (IO Controller assigns input and output 1-4 values)
- 1 = RETA-02 configuration parameters 18-25 are used
- 2 = Disable (Use 'Input/Output 1-4 parameter source selection' parameter of the initial record data to select the source for the first four inputs and output)

Network configuration


Overview

RETA-02 supports 10 Mbit/s and 100 Mbit/s data transfer rates and automatically detects the data transfer rate used in the network.

Note: PROFINET IO uses only 100 Mbit/s in Full-duplex mode.

The network configuration of the RETA-02 can be done using several methods. The following flowchart shows the sequence in which different settings are read. The table below gives detailed information on each different configuration methods.

IP settings configuration



Method	Description	Note												
DIP switch (S1)	By default, the IP address is defined by software. Setting any DIP actuator to ON enables hardware selection. DIP actuators 1 to 8 define the last octet (1 to 254) of the IP address in binary. Actuator 8 represents the least significant bit.													
	IP address:	192.168.0.xxx												
	Subnet mask:	255.255.255.0												
	Gateway:	0.0.0.0												
	where xxx stands for a value between 1 and 254 and is selected by DIP switch S1. Example DIP settings:													
	<table><tr><th>Intranet IP address</th><th>S1 actuator positions</th></tr><tr><td>(Selected by software)</td><td>OFF 00000000 ON 12345678</td></tr><tr><td>192.168.0.1</td><td>OFF 00000000 ON 0 12345678</td></tr><tr><td>192.168.0.2</td><td>OFF 000000 0 ON 0 12345678</td></tr><tr><td>...</td><td>...</td></tr><tr><td>192.168.0.255</td><td>OFF ON 00000000 12345678</td></tr></table>		Intranet IP address	S1 actuator positions	(Selected by software)	OFF 00000000 ON 12345678	192.168.0.1	OFF 00000000 ON 0 12345678	192.168.0.2	OFF 000000 0 ON 0 12345678	...	...	192.168.0.255	OFF ON 00000000 12345678
	Intranet IP address	S1 actuator positions												
(Selected by software)	OFF 00000000 ON 12345678													
192.168.0.1	OFF 00000000 ON 0 12345678													
192.168.0.2	OFF 000000 0 ON 0 12345678													
...	...													
192.168.0.255	OFF ON 00000000 12345678													
DHCP/BOOTP	Automatically receive the configuration from a DHCP server.	A DHCP server is required on the network.												

Method	Description	Note
Settings stored in RETA-02 configuration parameters	Use the configuration stored in the RETA-02 configuration parameters. See Table 4. in chapter Drive configuration .	RETA-02 must be started for any configuration changes to take effect.
Gleaning (ARP)	Change the IP address from a PC using the following commands: <pre>arp -s <IP address> <MAC address> ping <IP address> arp -d <IP address></pre> The <code>arp -s</code> command will store the IP and MAC addresses in the PC ARP table. When the <code>ping</code> command is executed, the PC will send the message to the module using the MAC address. The module changes its IP address to the given one.	The MAC address of the module can be found on a label on the RETA-02 module.
DCP (Discovery and Configuration Protocol)	The DCP protocol is used for setting the IP address and for assigning a station name of a PROFINET IO node.	Usually included to a configuration tool, like Step7. This protocol cannot be used with Modbus/TCP.

PROFINET IO and DCP

DCP can only be used in the PROFINET IO mode. When the module is initialized, the IP address is transferred to the PROFINET IO communication stack. If there is a need to change the IP address it should be done with a DCP tool (like Siemens Step7). If some of the other methods is used to change the IP address, the module must be restarted to enable any changes.

Duplicate IP address detection

RETA-02 has a duplicate IP address detection mechanism when using Modbus/TCP. If the module detects another device on the network, which has the same IP address, it lids the Network status led in red and starts to blink the Module status led in red.

In PROFINET IO network the controller has the duplicate IP address detection mechanism.

Master configuration

Overview

This chapter describes the principle of configuring the PROFINET IO master station for communication through the RETA-02 PROFINET IO Adapter module.

Configuring the system

After the RETA-02 PROFINET IO Adapter module has been mechanically and electrically installed according to the instructions in previous chapters, and has been initialised by the drive, the master station must be prepared for communication with the module.

Configuration of the master station requires a type definition (GSD) file. In PROFINET IO the GSD file is written in XML based language called GSDML. RETA-02 has a GSD file, which is available from www.profinet.com, www.abb.com or your local ABB representative. The filename is **GSDML-Vx.x-ABB-RETA02-yyyymmdd.xml**.

The GSD file describes vendor specific features and PROFIdrive specific features of the adapter. Vendor specific features can be used e.g. in ABB Drives communication profile. PROFIdrive mode supports a set of services described in the PROFIdrive specification.

Please refer to the master station documentation for more information on activating PROFINET IO devices with GSD file.

System requirements

To use the vendor specific features the master station should support GSDML v1.0 and one subslot per slot. To use the PROFIdrive mode the master system should support GSDML 2.0 or 2.1 and multiple subslots per slot.

Communication profiles

Overview

This chapter describes the communication profiles used in the communication between the PROFINET IO network, the RETA-02 module, and the drive.

Communication profiles

Communication profiles are ways of conveying control commands (Control word, Status word, references and actual values) between the master station and the drive. With the RETA-02 module, the PROFINET IO network may employ either the PROFIdrive profile or the ABB Drives profile.

The following sections describe the Control word, the Status word, references and actual values for the PROFIdrive and ABB Drives communication profiles.

The PROFIdrive communication profile

The Control Word and the Status Word

The Control Word is the principal means for controlling the drive from a fieldbus system. It is sent by the fieldbus master station to the drive through the adapter module. The drive switches between its states according to the bit-coded instructions on the Control Word, and returns status information to the master in the Status Word.

The contents of the Control Word and the Status Word are detailed in [Table 5](#). and [Table 6](#). respectively; see the drive documentation for information on the drive-specific bits. The drive states are presented in the PROFIdrive State Machine ([Figure 11](#).).


References

References are 16-bit words containing a sign bit and a 15-bit integer. A negative reference (indicating reversed direction of rotation) is formed by calculating the two's complement from the corresponding positive reference.

ABB drives can receive control information from multiple sources including analogue and digital inputs, the drive control panel and a communication module (e.g. RETA-02). In order to have the drive controlled through PROFINET IO, the communication module must be defined as the source for control information, e.g. Reference.

Scaling

The speed reference (REF) in hexadecimal (0 ... 4000h) corresponds to 0 ... 100% of Nominal Speed or Maximum Reference depending on the drive type.



Actual values

Actual values are 16-bit words containing information on the operation of the drive. The functions to be monitored are selected by a drive parameter.

Scaling

The actual speed (ACT) in hexadecimal (0 ... 4000h) corresponds to 0 ... 100% of Nominal Speed or Maximum Reference depending on the drive type.




Table 5. The Control Word for the PROFIdrive communication profile. The upper case boldface text refers to the states shown in Figure 11.

Bit	Name	Value	Proceed to STATE/Description
0	ON	1	Proceed to READY TO OPERATE .
	OFF1	0	Emergency OFF, stop by the selected deceleration ramp. Proceed to OFF1 ACTIVE ; proceed further to READY TO SWITCH ON unless other interlocks (OFF2, OFF3) are active.
1	OFF2	1	Continue operation (OFF2 inactive).
		0	Emergency OFF, coast to stop. Proceed to OFF2 ACTIVE ; proceed further to SWITCH-ON INHIBIT .
2	OFF3	1	Continue operation (OFF3 inactive).
		0	Emergency stop, stop according to fastest possible deceleration mode. Proceed to OFF3 ACTIVE ; proceed further to SWITCH-ON INHIBIT . Warning: Ensure motor and driven machine can be stopped using this stop mode.
3	OPERATION_ENABLE	1	Proceed to ENABLE OPERATION .
		0	Inhibit operation. Proceed to OPERATION INHIBIT .
4	RAMP_OUT_ZERO	1	Normal operation. Proceed to RAMP FUNCTION GENERATOR: ENABLE OUTPUT .
		0	Stop according to selected stop type.
5	RAMP_HOLD	1	Normal operation. Proceed to RAMP FUNCTION GENERATOR: ENABLE ACCELERATOR .
		0	Halt ramping (Ramp Function Generator output held).
6	RAMP_IN_ZERO	1	Normal operation. Proceed to OPERATING . Note: This bit is effective only if the fieldbus interface is set as the source for this signal by drive parameters.
		0	Force Ramp Function Generator input to zero.

Bit	Name	Value	Proceed to STATE/Description
7	RESET	0 $\Rightarrow$ 1	Fault reset if an active fault exists. Proceed to SWITCH-ON INHIBIT . Note: This bit is effective only if the fieldbus interface is set as the source for this signal by drive parameters.
		0	(Continue normal operation)
8	INCHING_1		Inching 1. (Not supported by all drive types)
9	INCHING_2		Inching 2. (Not supported by all drive types)
10	REMOTE_CMD	1	Fieldbus control enabled.
		0	Control Word $\neq$ 0 or Reference $\neq$ 0: Retain last Control Word and Reference. Control Word = 0 and Reference = 0: Fieldbus control enabled.
11 to 15			Drive specific

Table 6. The Status Word for the PROFIdrive communication profile. The upper case boldface text refers to the states shown in Figure 11.

Bit	Name	Value	STATE/Description
0	RDY_ON	1	READY TO SWITCH ON.
		0	NOT READY TO SWITCH ON.
1	RDY_RUN	1	READY TO OPERATE.
		0	OFF1 ACTIVE.
2	RDY_REF	1	ENABLE OPERATION.
		0	DISABLE OPERATION.
3	TRIPPED	1	FAULT.
		0	No fault.
4	OFF_2_STA	1	OFF2 inactive.
		0	OFF2 ACTIVE.
5	OFF_3_STA	1	OFF3 inactive.
		0	OFF3 ACTIVE.
6	SWC_ON_INHIB	1	SWITCH-ON INHIBIT ACTIVE.
		0	SWITCH-ON INHIBIT NOT ACTIVE.
7	ALARM	1	Warning/Alarm.
		0	No Warning/Alarm.
8	AT_SETPOINT	1	OPERATING. Actual value equals reference value (i.e. is within tolerance limits).
		0	Actual value differs from reference value (= is outside tolerance limits).
9	REMOTE	1	Drive control location: REMOTE.
		0	Drive control location: LOCAL.
10	ABOVE_LIMIT	1	Actual frequency or speed value equals or is greater than supervision limit.
		0	Actual frequency or speed value is within supervision limit.

Bit	Name	Value	STATE/Description
11 to 15			Drive specific




Figure 11. The PROFdrive state machine

The ABB Drives communication profile

The Control Word and the Status Word

The Control Word is the principal means for controlling the drive from a fieldbus system. It is sent by the fieldbus master station to the drive through the adapter module. The drive switches between its states according to the bit-coded instructions on the Control Word, and returns status information to the master in the Status Word.

The contents of the Control Word and the Status Word are detailed in [Table 7.](#) and [Table 8.](#) respectively. The drive states are presented in the ABB Drives profile state machine ([Figure 12.](#)).

References


References are 16-bit words containing a sign bit and a 15-bit integer. A negative reference (indicating reversed direction of rotation) is formed by calculating the two's complement from the corresponding positive reference.

ABB drives can receive control information from multiple sources including analogue and digital inputs, the drive control panel and a communication module (e.g. RETA-02). In order to have the drive controlled through the fieldbus, the module must be defined as the source for control information, e.g. Reference.

Scaling

References are scaled as shown below.

Note: The values of REF1 MAX and REF2 MAX are set by drive parameters. See the drive documentation for further information.



Actual values

Actual values are 16-bit words containing information on the operation of the drive. The functions to be monitored are selected by a drive parameter.

Scaling

Actual values are scaled as shown below.

Note: The values of REF1 MAX and REF2 MAX are set by drive parameters. See the drive documentation for further information.




Table 7. The Control Word for the ABB Drives communication profile. The upper case boldface text refers to the states shown in Figure 11.

Bit	Name	Value	STATE/Description
0	OFF1_ CONTROL	1	Proceed to READY TO OPERATE .
		0	Stop along currently active deceleration ramp. Proceed to OFF1 ACTIVE ; proceed to READY TO SWITCH ON unless other interlocks (OFF2, OFF3) are active.
1	OFF2_ CONTROL	1	Continue operation (OFF2 inactive).
		0	Emergency OFF, coast to stop. Proceed to OFF2 ACTIVE , proceed to SWITCH-ON INHIBITED .
2	OFF3_ CONTROL	1	Continue operation (OFF3 inactive).
		0	Emergency stop, stop within time defined by drive parameter. Proceed to OFF3 ACTIVE ; proceed to SWITCH-ON INHIBITED . Warning: Ensure motor and driven machine can be stopped using this stop mode.
3	INHIBIT_ OPERATION	1	Proceed to OPERATION ENABLED . Note: Run enable signal must be active; see drive documentation. If the drive is set to receive the Run enable signal from the fieldbus, this bit activates the signal.
		0	Inhibit operation. Proceed to OPERATION INHIBITED .
4	RAMP_OUT_ ZERO	1	Normal operation. Proceed to RAMP FUNCTION GENERATOR: OUTPUT ENABLED .
		0	Force Ramp Function Generator output to zero. Drive ramps to stop (current and DC voltage limits in force).

Bit	Name	Value	STATE/Description
5	RAMP_HOLD	1	Enable ramp function. Proceed to RAMP FUNCTION GENERATOR: ACCELERATOR ENABLED.
		0	Halt ramping (Ramp Function Generator output held).
6	RAMP_IN_ZERO	1	Normal operation. Proceed to OPERATING. Note: This bit is effective only if the fieldbus interface is set as the source for this signal by drive parameters.
		0	Force Ramp Function Generator input to zero.
7	RESET	0=>1	Fault reset if an active fault exists. Proceed to SWITCH-ON INHIBITED. Note: This bit is effective only if the fieldbus interface is set as the source for this signal by drive parameters.
		0	Continue normal operation.
8 to 9	Reserved.		
10	REMOTE_CMD	1	Fieldbus control enabled.
		0	Control Word <> 0 or Reference <> 0: Retain last Control Word and Reference. Control Word = 0 and Reference = 0: Fieldbus control enabled. Reference and deceleration/acceleration ramp are locked.
11	EXT_CTRL_LOC	1	Select External Control Location EXT2. Effective if control location parameterised to be selected from fieldbus.
		0	Select External Control Location EXT1. Effective if control location parameterised to be selected from fieldbus.
12 to 15	Reserved.		

Table 8. The Status Word for the ABB Drives communication profile. The upper case boldface text refers to the states shown in Figure 12.

Bit	Name	Value	STATE/Description
0	RDY_ON	1	READY TO SWITCH ON.
		0	NOT READY TO SWITCH ON.
1	RDY_RUN	1	READY TO OPERATE.
		0	OFF1 ACTIVE.
2	RDY_REF	1	OPERATION ENABLED.
		0	OPERATION INHIBITED.
3	TRIPPED	1	FAULT.
		0	No fault.
4	OFF_2_STA	1	OFF2 inactive.
		0	OFF2 ACTIVE.
5	OFF_3_STA	1	OFF3 inactive.
		0	OFF3 ACTIVE.
6	SWC_ON_INHIB	1	SWITCH-ON INHIBITED.
		0	–
7	ALARM	1	Warning/Alarm.
		0	No warning/alarm.
8	AT_SETPOINT	1	OPERATING. Actual value equals reference = is within tolerance limits, i.e. in speed control, speed error is 10% max. of nominal motor speed.
		0	Actual value differs from reference = is outside tolerance limits.
9	REMOTE	1	Drive control location: REMOTE (EXT1 or EXT2).
		0	Drive control location: LOCAL.

Bit	Name	Value	STATE/Description
10	ABOVE_ LIMIT	1	Actual frequency or speed equals or exceeds supervision limit (set by drive parameter). Valid in both directions of rotation.
		0	Actual frequency or speed within supervision limit.
11	EXT_CTRL_ LOC	1	External Control Location EXT2 selected.
		0	External Control Location EXT1 selected.
13 to 14	Reserved.		
15		1	Communication error detected by fieldbus adapter module.
		0	Fieldbus adapter communication OK.

Communication

Overview

This chapter describes the Modbus/TCP and PROFINET IO messaging used in the communication with the drive.

Protocols

The RETA-02 module supports the Modbus/TCP protocol according to Modbus/TCP Specification 1.0, and the PROFINET IO protocol. Protocol can be selected with a parameter PROTOCOL.

Selection parameter 51.16 (PROTOCOL)	Communication protocol
0	Modbus/TCP
1	PROFINET IO

Modbus/TCP

Register read and write

The drive parameter and data set information is mapped into a 4xxxx register area. This holding register area can be read from an external device, and an external device can modify the register values by writing to them.

There are no set-up parameters for mapping the data to the 4xxxx register area. The mapping is predefined and corresponds directly to the drive parameter grouping.

All mapped parameters are available for reading. The parameter writes are verified for correct value, and for valid register addresses. Some parameters never allow writing (e.g. actual signals), some allow writing only when the drive is stopped (e.g. set-up variables), and some can be modified at any time (e.g. actual reference values).

Note: Some of the drive parameters are not accessible via fieldbus. These are e.g. 32 bit parameters.

Register mapping

The drive parameters are mapped to the 4xxxx area as follows:

40001...40096 are reserved for data sets

40101...49999 are reserved for parameters.

In this mapping, the thousands and hundreds correspond to the group number, while the tens and ones correspond to the parameter number within a group. Register addresses 4GGPP are shown in the table below. In the table, GG represents the group number while PP is the parameter index within the group.

Table 9. Parameter mapping

Parameter	4GGPP	GG	PP
Data sets Each data set consists of 3 data words. For example, 'Data word 2.3' refers to the 3rd word in data set 2.	40001...40096	00 Data sets	01 Data word 1.1 02 Data word 1.2 03 Data word 1.3 04 Data word 2.1 05 Data word 2.2 06 Data word 2.3 07 Data word 3.1 ... 94 Data word 32.1 95 Data word 32.2 96 Data word 32.3
Parameters	40101...40199	01 Group 01	01 Index 01 02 Index 02 ... 99 Index 99
	40201...40299	02 Group 02	01 Index 01 02 Index 02 ... 99 Index 99
	...	...	...
	49901...49999	99 Group 99	01 Index 01 02 Index 02 ... 99 Index 99

Register addresses, which are not allocated to any drive parameter or data set, are invalid. Attempting to read from or write to such an address will make the Modbus/TCP interface return an exception code to the controller.

Refer to the drive manuals for drive-specific information such as the data sets supported, and parameter numbers. Data set registers are updated in a cyclic interval. Updating of parameter registers happens at a slower interval.

Exception codes

The RETA-02 supports the Modbus exception codes shown below.

Table 10. Supported exception codes

Exception code	Name	Description
01	Illegal function	Unsupported command
02	Illegal data address	Address does not exist or is read/write-protected
03	Illegal data value	Value is outside minimum and maximum limits. Parameter is read-only

Function codes

The RETA-02 supports the Modbus function codes shown below.

Table 11. Supported function codes

Function code	Name	Description	Modbus class
03	Read holding registers	Reads the binary contents of the holding registers (4X references) in the slave.	0
06	Preset single register	Presets a value into a single holding register (4X reference).	1
16 (10h)	Preset multiple registers	Presets values into a sequence of holding registers (4X references).	0
23 (17h)	Read/Write registers	Performs a combination of one read and one write operation in a single Modbus transaction. The function first reads a group of 4XXXX registers and then writes new contents to a another group of 4XXXX registers.	2

PROFINET IO

Overview

This chapter describes the PROFINET IO communication protocol for RETA-02. For detailed information on PROFINET IO communication, refer to *PROFINET specification Application Layer protocol for decentralized periphery and distributed automation v2.0*.

Introduction to PROFINET IO

PROFINET IO is a fieldbus protocol that enables communication between programmable controllers and distributed field devices in Ethernet network. The protocol classifies devices into IO controllers, IO supervisors and IO devices, which have a specific collection of services.

PROFINET IO uses three different communication channels to exchange data. The standard UDP/IP and TCP/IP channel is used for parameterization and configuration of devices and for acyclic operations. The Real Time (RT) channel is used for cyclic data transfer and alarms. The third channel, Isochronous Real Time (IRT) channel, is used e.g. in motion control applications (not implemented in RETA-02).

PROFINET IO devices are structured in slots, sub-slots, which can contain modules and submodules correspondingly. Device can have almost any number of slots and sub-slots and they can be virtual or real. Device specific data is represented in slot 0, module and submodule specific data in subsequent slots and sub-slots.

One of the benefits of PROFINET IO is the diagnostics and alarm mechanism. Every module and sub-module provide alarm data to the IO controller using the cyclic channel. Diagnostic data can be read non-cyclically from the device by using record data.

Properties and services of a PROFINET IO device are described in a GSD file that is written in GSDML (General Station Description Markup Language). GSD file describes the device specific

modules and the method of assigning modules and sub-modules to predefined slots and sub-slots. For more information see chapter [Master configuration](#).

PROFINET IO in RETA-02

When PROFINET IO is selected as the communication protocol RETA-02 adapter can operate in two modes, Vendor mode and PROFIdrive mode. The mode can be selected with a GSD file in a PROFINET IO hardware configuration tool. User can select the appropriate device access point (DAP) and functional module with the tool as well.

RETA-02 uses slots 0 and 1. Slot 0 doesn't have any sub-slots and the DAP module attached to it represents the device itself. Other functional modules and sub-modules, which are described in the GSD file can be assigned to slot 1 and its sub-slots. In Vendor mode:

- Slot 0 = Device access point (DAP)
- Slot 1, sub-slot 1 = Vendor object (PPO types)
- Slot 1, sub-slot 1 = Acyclic parameter access (MAP/PAP)

In PROFIdrive mode:

- Slot 0 = Device access point
- Slot 1 = Drive Object
- Slot 1, sub-slot 1 = Acyclic parameter access (MAP/PAP)
- Slot 1, sub-slot 2 = Standard telegram 1
- Slot 1, sub-slots 3-18 = Freely configurable inputs and outputs

RETA-02 adapter provides the following services:

- Cyclic messaging in Vendor mode (e.g. ABB Drives profile)
- Cyclic messaging in PROFIdrive mode
- Acyclic parameter access mechanism
- Identification & Maintenance functions (I&M)
- PROFIdrive parameters (limited in Vendor mode)
- Diagnostic and alarm mechanism (Only in PROFIdrive mode)
- Fault buffer mechanism (limited in Vendor mode)


Note: Only part of the PROFIdrive parameters are supported in the Vendor mode. See section [PROFIdrive profile-specific parameters](#) for more information.

Cyclic messaging in Vendor mode

In vendor mode the drive can be controlled according to ABB Drives communication profile.

PPO types

The adapter has three different PPO types, which differ only by the amount of freely configurable inputs and outputs.



OUT area – Data sent from Master to Slave (control data)

IN area – Data sent from Slave to Master (actual data)

Process Data:

CW – Control Word

SW – Status Word

REF – Reference

ACT – Actual Value

PZD – Process Data (application-specific)

Cyclic messaging in PROFIdrive mode

Standard telegram 1

RETA-02 supports Standard telegram 1. It is possible to add inputs and outputs as separate PZD's. GSD file contains special collections where standard telegram 1 has been extended with inputs and outputs.

		PZD1	PZD2
Standard telegram 1	OUT area	Control Word	Speed set-point
	IN area	Status Word	Speed actual value


Note: For the contents of the Control Word, the Status Word, References, and Actual Values, see the chapter [Communication profiles](#).

Acyclic parameter access mechanism

Acyclic parameter access mechanism can be used to access PROFIdrive parameters, drive parameters and the Identification & Maintenance functions.

Note: Acyclic parameter access mechanism can have delays up to two seconds and thus should not be used for time-critical data.

Requests and responses between the IO device and the IO controller or the IO supervisor are transferred with the Record Data Objects.




A write request is first sent containing the parameter request.

If the write request is valid, the RETA-02 acknowledges it with request accepted. The master should then send a read request. If the RETA-02 is still busy performing the internal parameter request, it will return a negative response with the error code 0xB5 (State conflict). In this case, the read request will be repeated by the master until the RETA-02 has the PROFIdrive response data ready.

If the write request is invalid, a negative response is returned with an error code.

Note: In IEC 61131-3 compatible systems function blocks are provided for accessing data non-cyclically. In Siemens S7, SFB 52 "RDREC" can be used for reading and SFB53 "WRREC" for writing Data Records.



For more information on above function blocks, see document *Communication Function Blocks for PROFIBUS DP and PROFINET IO v2.0* available at www.profibus.com.

Supported Record Data Objects and their indices are listed in the table below.

Table 12.Record Data Objects

Parameter Access Service	Index
Base Mode Parameter Access - Local	0xB02E
Base Mode Parameter Access - Global	0xB02F
User Specific Record Data (For compatibility reasons)	0x2F

Base Mode Parameter Access - Local

The DO-ID field in the Record Data Object request header is not evaluated by the parameter manager and a valid Parameter Access Point (PAP) should be used to access record data. The PAP is located in subslot 1 of the slot 1.

Base Mode Parameter Access - Global

The slot and subslot fields in the Record Data Object request header are not evaluated by the parameter manager. The DO-ID is used instead and it should have either value 0x00 or 0x01.

User Specific Record Data

User Specific Record Data can be used for global parameter access. This index is supported for compatibility reasons.

Header and frame structures

PROFINET IO uses DCE RPC (Distributed Computing Environment Remote Procedure Call) protocol for acyclic read and acyclic write services. IO controllers and supervisors will take care of formulating most of the request frames. However, it is possible that handling the PROFINET request and response headers must be performed in the application logic. The acyclic frame structure, headers and error codes are described further below.

Table 13. Ethernet frame structure

Frames	Dest addr.	Src addr.	Ether type	IP UDP	RPC	NDR	Read or Write	Data
Bytes	6	6	2	28	80	20	64	...

Dest addr. and the **Src addr.** are the destination and the source of the communication relationship. The addresses are in hexadecimal format, e.g. 00-30-11-02-57-AD.

Ether type is 0x800 for non-real-time communication.

IP and **UDP** fields contain the IP address of the source and the destination as well as the communication ports and length of the message.


RPC contains for example the *read* or *write* service ID, interface description and selected objects.

NDR request block describes the length of the following data block. The response block also contains bytes *ErrorCode*, *ErrorDecode*, *ErrorCode1* and *ErrorCode2* for presenting the status of the request.

Table 14. Response error codes

Byte	Value and meaning
ErrorCode	0xDF (Error Write)
	0xDE (Error Read)
ErrorDecode	0x80 (PNIORW) ErrorCode1 decoded according to Table 15 . ErrorCode2 is '0'.
	0x81 (PNIO) ErrorCode1 and ErrorCode2 decoded according to Table 15 .
ErrorCode1	Error class and error code (see Table 15 below).
ErrorCode2	Not described here

Table 15. *ErrorCode1* with *PNIORW* decoding

		
Error class	Meaning	Error code
0 ... 9	(Reserved)	
10 (0x0A)	Application	0 = Read error 1 = Write error 2 = Module failure 3 ... 7 = Reserved 8 = Version conflict 9 = Feature not supported 10 ... 15 = User-specific
11 (0x0B)	Access	0 = Invalid index 1 = Write length error 2 = Invalid slot 3 = Type conflict 4 = Invalid area 5 = State conflict 6 = Access denied 7 = Invalid range 8 = Invalid parameter 9 = Invalid type 10 ... 15 = User-specific
12 (0x0C)	Resource	0 = Read constraint conflict 1 = Write constraint conflict 2 = Resource busy 3 = Resource unavailable 4 ... 7 = Reserved 8 ... 15 = User-specific
13 ... 15	User-specific	

Read block is used in read requests and responses. **Write** block is used in write requests and responses. The request consists of

unique identifiers for the connection, addressing information and length of the record data. The response also contains two additional fields for transferring information. See [Table 16.](#) for details.

Table 16. Structure of the Read and Write blocks

Field(s)	Description	Range	Type
Service	Request or Response service.	Request (0x00) Response (0x80)	UI8
Operation	Read or Write operation.	Write (0x08) Read (0x09)	UI8
Block length	Length of the block.	0 ... 0xFFFF	UI16
ARUUID	Identifier - time low - time mid - time high and version - clock - node		UI32 UI16 UI16 Octet[2] Octet[6]
API	Application Process Identifier	Device Access Point (0x0000) PROFIdrive (0x3A00)	UI32
Slot	Slot of the Module Access Point (MAP/PAP)	0x01	UI16
Subslot	Subslot of the Module Access Point (MAP/PAP)	0x01	UI16
Padding	2 bytes		
Index	Index of the Record Data Object	0x2F 0xB02E 0xB02F	UI16
Data length	Length of the data block	0...0xFFFFFFFF	UI32

Additional value 1 (response only)	Field for transferring additional data		UI16
Additional value 2 (response only)	Field for transferring additional data		UI16
Padding	24 bytes for request, 20 bytes for response.		
Data block	Used only with write request and read response.		

Data block contains PROFIdrive specific request or response header. See below for more details.

Table 17. PROFIdrive Request header

Field(s)	Description	Range	Byte/ Word
Request Reference	Unique identification set by the master. Changed for each new request.	1 ... 255	Byte
Request ID	Request type for the issued block.	Request Parameter (0x01) Change Parameter (0x02)	Byte
DO-ID	To be set to 0x01.	0 ... 255	Byte
No. of Parameters	Number of parameters that are present in the request.	1 ... 37	Byte
Attribute	Type of object being accessed. Note: "Text" is not supported.	Value (0x10) Description (0x20) Text (0x30)	Byte
No. of Elements	Number of array elements accessed or length of string accessed. Set to 0 if non-array parameters are used.	0, 1 ... 234	Byte
Parameter Index (group)	Address of the PROFIdrive parameter that is being accessed. Also "0" is allowed by RETA-02. Parameter group of the drive when accessing drive parameters.	1 ... 65535	Word
Subindex (parameter)	Addresses the first array element of the parameter or the beginning of a string access or the text array, or the description element that is being accessed. Parameter number if accessing drive parameters.	0 ... 65535	Word
Format*	See Table 21 .	See Table 21 .	Byte
Number of Values*	Number of values following.	0 ... 234	Byte

Values*	The values of the request. In case of odd number of bytes, a zero byte is appended to ensure the word structure of the telegram.	–	See Format field
*Only if Request ID is 0x02 (Change Parameter). The Format, Number of Values and Values fields are repeated for other parameters.			

Table 18. PROFIdrive Response header

Field(s)	Description	Range
Response Reference	Mirrored from the request.	1 ... 255
Response ID	Response from the slave. In case any requested services fail, a “not acknowledged” (NAK) response will be indicated.	Request Param OK (0x01) Request Param NAK (0x81) Change Param OK (0x02) Change Param NAK (0x82)
DO-ID	To be set to 1.	0 ... 255
No. of Parameters	Number of parameters that are present in the response.	1 ... 37
Format*	See Table 21 .	See Table 21 .
Number of Values*	Number of values following.	0 ... 234
Values*	The values of the request. In case of odd number of bytes, a zero byte is appended to ensure the word structure of the telegram.	–
*Only if Response ID is 0x01 (Request Parameter OK). The Format, Number of Values and Values fields are repeated for other parameters.		

Table 19. Data types for Format field

Code	Type
0x00	(Reserved)
0x01...0x36	Standard data types
0x37...0x3F	(Reserved)
0x40	Zero
0x41	Byte
0x42	Word
0x43	Double word
0x44	Error
0x45 ... 0xFF	(Reserved)

Table 20. PROFIdrive Parameter Request error codes

Error #	Meaning	Used at
0x00	Impermissible parameter number	Access to unavailable parameter
0x01	Parameter value cannot be changed	Change access to a parameter value that cannot be changed
0x02	Low or high limit exceeded	Change access with value outside the limits
0x03	Invalid subindex	Access to unavailable subindex
0x04	No array	Access with subindex to non-indexed parameter
0x05	Incorrect data type	Change access with value that does not match the data type of the parameter
0x06	Setting not permitted (can only be reset)	Change access with value unequal to 0 when this is not permitted
0x07	Description element cannot be changed	Change access to a description element that cannot be changed
0x09	No description data available	Access to unavailable description (parameter value is available)
0x0B	No operation priority	Change access rights without rights to change parameters
0x0F	No text array available	Access to text array that is not available (parameter value is available)
0x11	Request cannot be executed because of operating mode	Access is temporarily not possible for reasons that are not specified in detail
0x14	Value impermissible	Change access with a value that is within limits but is not permissible for other long-term reasons (parameter with defined single values)
0x15	Response too long	The length of the current response exceeds the maximum transmittable length

0x16	Parameter address impermissible	Illegal value or value that is not supported for the attribute, number of elements, parameter number or sub-index, or a combination
0x17	Illegal format	Write request: Illegal format or format of parameter data that is not supported
0x18	Number of values inconsistent	Write request: Number of values of parameter data does not match number of elements at the parameter address
0x19	DO nonexistent	Request to DO, which does not exist
0x65... 0xFF	Manufacturer-specific	—
0x65	Vendor-specific error	Vendor-specific error
0x66	Request not supported	Request not supported
0x67	Communication error	Request cannot be completed because of communication error
0x6F	Time-out error	Request aborted due to time-out
0x78	PZD map failure	Parameter cannot be mapped to PZD (size mismatch or non-existent)
0x79	PZD memory failure	Parameter cannot be mapped to PZD (out of memory)
0x7A	Multiple PZD map	Parameter cannot be mapped to PZD (multiple PZD write)
0x8C	Set torque mode error	Cannot change mode to TORQUE (frequency is used)
0x90	Illegal Request ID	The request ID of the response is illegal

Parameter data transfer examples


The following example shows how parameter data is transferred using the acyclic parameter access mechanism's READ and WRITE.

Note: Only the part of the acyclic frame is presented in the examples. The padding zeroes are not presented.


Example 1: Reading a drive parameter

To determine the parameter number and subindex for drive parameter reading, multiply the parameter number by one hundred and then convert it to hexadecimal. The low byte is the subindex (IND), and the high byte is the parameter index (PNU). For example, drive parameter number 12.04 corresponds to $12.04 \times 100 = 1204 = 0x04B4$.


Write request (Read parameter value):



Positive Read response to Read request:



Negative response to PROFIdrive Read request:



Identification and maintenance functions (I&M)

The purpose of the I&M functions is to provide support for the customer during commissioning, parametrization and repair of the module. RETA-02 supports I&M functions 0 - 4, which can be accessed with a qualified configuration tool (like DTM Tool) or using the Record data object's read request.

Function	Record Data Index
I&M 0	0xAFF0
I&M 1	0xAFF1
I&M 2	0xAFF2
I&M 3	0xAFF3
I&M 4	0xAFF4

Structure of the I&M functions is described in the following tables.

I&M0 Device identification (read-only)

Content	Size	Description
Header	10 bytes	-
Vendor ID	2 bytes	PROFINET Vendor ID of ABB, which is 26 (0x001A)
Order ID	20 bytes	Order number of the RETA-02 adapter kit
Serial number	16 bytes	Serial number of the adapter
Hardware revision	2 bytes	Hardware revision of the RETA-02 adapter
Software revision	4 bytes	Revision of the software
Revision counter	2 bytes	Number of revision
Profile ID	2 bytes	PROFIdrive (0x3A00)
Profile specific type	2 types	No profile specific type (0x0000)
I&M version	2 types	Version is 1.1 (0x0101)
Supported I&M functions	2 types	I&M0-I&M4 are supported (0x0017)

I&M1 Task identification

Content	Size	Description
Header	10 bytes	-
TAG_FUNCTION	32 bytes	The function or task of the drive can be described here
TAG_LOCATION	22 bytes	The location of the drive can be described here

I&M2 Installation date

Content	Size	Description
Header	10 bytes	-
INSTALLATION_DATE	16 bytes	This parameter indicates the date and time of installation. Date and time according to ISO 8601. Example: 2007-02-28 13:30 (YYYY-MM-DD hh:mm)

I&M3 Additional data

Content	Size	Description
Header	10 bytes	-
DESCRIPTOR	54 bytes	Any additional data set by the user

I&M4 Signature

Content	Size	Description
Header	10 bytes	-
SIGNATURE	54 bytes	Security code for identifying sessions and changes

PROFIdrive profile-specific parameters

PROFIdrive parameters contain data of the drive in standard form.
The table below describes the supported PROFIdrive parameters.

Parameter	Mode ***	R/W*	Data type	Description
915	V/P	R	Array [10] Unsigned16	Assignment PZD1 to PZD10 in setpoint telegram
916	V/P	R/	Array [10] Unsigned16	Assignment PZD1 to PZD10 in actual value telegram
919	V/P	R	Visible String16	Device system number.
922	P	R	Unsigned16	Telegram selection
923	P	R	Array[n]Unsigned16	List of all parameters for signals
927	V/P	R/W	Unsigned16	Operator control rights Value Mode 0 Parameters cannot be written, only read (927 can be written) 1 Parameters can be written and read (default).

Para- meter	Mode ***	R/W*	Data type	Description	
928	P	R/W	Unsigned16	Control rights (process data, PZD).	
				Value	Mode
				0	No control through the PROFINET IO. Setpoint telegram not used.
				1	IO-controller will control the drive through IO data (default)
				2	IO-supervisor will control the drive through parameters 900 and 907 (Not supported at)
930	P	R/W	Unsigned16	Selection switch for operating mode. Value Mode 1 Speed control mode 0x8001 Torque control mode	
944	V/P	R	Unsigned16	Fault message counter	
945	V/P	R	Array[64] Unsigned16	Fault code (Channel Error Type, table 23). Note: The drive may limit the actual number of faults recorded. Subindex Contents 0 Active fault 8 **Last ackn. fault 16 **Second last ackn. fault 24 **Third last ackn. fault 32 **Fourth last ackn. fault 40 **Fifth last ackn. fault	
946	V/P	R	Array[n] Unsigned16	Fault code list. Fault code list contains mapping between DRIVECOM fault codes and Channel Error Types. Using DRIVECOM fault code as an index when reading PNU946 the corresponding Channel Error Type is returned.	

Parameter	Mode ***	R/W*	Data type	Description
947	V/P	R	Array [64] Unsigned16	Fault number. (coded according to DRIVECOM profile) Subindex Contents See parameter 945.
948	V/P	R	Array [n] TimeDifference	Fault time
952	V/P	R/W	Unsigned16	Number of faults occurred. Writing a zero clears the value.
953	V/P	R	Unsigned16	**Last alarm
954	V/P	R	Unsigned16	**Second last alarm
955	V/P	R	Unsigned16	**Third last alarm
956	V/P	R	Unsigned16	**Fourth last alarm
957	V/P	R	Unsigned16	**Fifth last alarm
964	V/P	R	Array [6] Unsigned16	Device identification Subindex Contents 0 Manufacturer 1 Device type 2 Version 3 Firmware date (year) 4 Firmware date (day/month) 5 Number of Drive Objects (DO)
965	P	R	Octet String2	Profile number of this device. 0329h = Profile 3, Version 41
967	V/P	R	Unsigned16	Control word (CW)
968	V/P	R	Unsigned16	Status word (SW)

Para- meter	Mode ***	R/W*	Data type	Description																		
972	V/P	R/W	Unsigned16	Software reset <table><tr><th>Value</th><th>Description</th></tr><tr><td>0</td><td>No action</td></tr><tr><td>1</td><td>Power-cycle PROFINET IO module</td></tr></table> The parameter must do a zero-to-one transition and the motor must be stopped.	Value	Description	0	No action	1	Power-cycle PROFINET IO module												
Value	Description																					
0	No action																					
1	Power-cycle PROFINET IO module																					
975	P	R	Array [8] Unsigned16	Drive Object identification <table><tr><th>Subindex</th><th>Contents</th></tr><tr><td>0</td><td>Manufacturer</td></tr><tr><td>1</td><td>DO type</td></tr><tr><td>2</td><td>Version</td></tr><tr><td>3</td><td>Firmware date (year)</td></tr><tr><td>4</td><td>Firmware date (day/month)</td></tr><tr><td>5</td><td>PROFIdrive DO type class (0x0001-Axis)</td></tr><tr><td>6</td><td>PROFIdrive DO sub-class 1(Application class</td></tr><tr><td>7</td><td>Drive Object ID (0x0001)</td></tr></table>	Subindex	Contents	0	Manufacturer	1	DO type	2	Version	3	Firmware date (year)	4	Firmware date (day/month)	5	PROFIdrive DO type class (0x0001-Axis)	6	PROFIdrive DO sub-class 1(Application class	7	Drive Object ID (0x0001)
Subindex	Contents																					
0	Manufacturer																					
1	DO type																					
2	Version																					
3	Firmware date (year)																					
4	Firmware date (day/month)																					
5	PROFIdrive DO type class (0x0001-Axis)																					
6	PROFIdrive DO sub-class 1(Application class																					
7	Drive Object ID (0x0001)																					
976	V/P	R/W	Unsigned16	Load device parameter set <table><tr><th>Value</th><th>Description</th></tr><tr><td>0</td><td>No action</td></tr><tr><td>1</td><td>Changes parameters to factory settings</td></tr></table> The parameter must do a zero-to-one transition and the motor must be	Value	Description	0	No action	1	Changes parameters to factory settings												
Value	Description																					
0	No action																					
1	Changes parameters to factory settings																					

Para- meter	Mode ***	R/W*	Data type	Description						
977	V/P	R/W	Unsigned16	Stores parameters to non-volatile memory <table><tr><th>Value</th><th>Description</th></tr><tr><td>0</td><td>No action</td></tr><tr><td>1</td><td>Stores parameters</td></tr></table> The parameter must do a zero-to-one transition and the motor must be	Value	Description	0	No action	1	Stores parameters
Value	Description									
0	No action									
1	Stores parameters									
978	P	R	Array [256] Unsigned8	List of Drive Object IDs (978[1] = 0x01, 978[2-255] = 0x00)						
980	P	R	Array [n] Unsigned16	Number list of defined PROFIdrive parameters						
...										
989	P	R	Array [n] Unsigned16	Number list of defined PROFIdrive parameters						
61000	V/P	R	VisibleString24	Name of station						
61001	V/P	R	Unsigned32	IP of station						
61002	V/P	R	Array [6] Unsigned8	MAC of station						
61003	V/P	R	Unsigned32	Default gateway of station						
61004	V/P	R	Unsigned32	Subnet mask of station						

* Read and/or Write

** Support depends on drive type

*** Supported in Vendor mode and/or PROFIdrive operating mode

Diagnostic and alarm mechanism

RETA-02 has mechanisms for sending alarms and saving diagnostics data to fault buffer. Alarm will be triggered if the host or drive has faults in communication or operation. There are three types of faults:

Fault	API / Slot / Subslot	Channel Error Type*
Temporary Host Communication Fault	0x000 / 0 / 1	INTCOMM
Permanent Host Communication Fault	0x000 / 0 / 1	INTCOMM
Drive Fault	0x3A00 / 1 / 1	See table 22.

* Channel Error Type is PROFIdrive profile specific. See list of Channel Error Types in the table below.

Alarm mechanism

When a fault situation occurs the RETA-02 adapter will send an alarm notification (see table below), which the master station has to acknowledge. Alarm notifications can be acknowledged, viewed and handled with e.g. Siemens S7 blocks OB82, OB83, OB86 and OB122. The block OB82 is used to make sure that the drive does not go to stop mode during a diagnostic alarm. The OB83 is called if module is inserted or removed from the system or if it is modified. OB86 indicates if there is a failure or event in the distributed periphery. If the CPU calls a device that is not accessible the OB122 is called.

Table 21. Alarm notification

Attribute	Description
BlockHeader	-
AlarmType	PROFINET specific alarm type
API	0x3A00 (PROFIdrive profile)
SlotNumber	Slot number of the Drive Object (DO)
SubslotNumber	Subslot number of the subslot where the diagnosis object is related to
ModuleIdentNumber	Module Ident number of the DO
SubmoduleIdentNumber	0xFFFF
AlarmSpecifier	Diagnosis type
UserStructureIdentifier	0x8000 (Channel Diagnosis Data)
ChannelNumber	0x8000 (whole submodule)
ChannelProperties	Structure describing the channel properties
ChannelErrorType	See Table 22 . below.

Table 22. Channel Error types

ChannelError Type	Abbreviation	Description	Corresponding DRIVECOM fault numbers*
0x9000	MICRO_HW	Microcontroller hardware or software	6000, 6010, 6100, 6306-630F, 6320
0x9001	MAINS	Mains supply	3210, 3211
0x9002	LOW_VOLT	Low voltage supply	3130, 3220
0x9003	DC_OVERV	DC link overvoltage	-
0x9004	POWER_ELEC	Power electronics	2211, 2212, 2300, 2310, 2312, 2340, 3381, 5410, 5441, 5442, 5481, 5482, 7110-7114
0x9005	OVERTEMP	Overtemperature electronic device	4110, 4210, 4280, 4310
0x9006	EARTH	Earth/ground fault	2330
0x9007	MOTOR_OVR	Motor overload	7121, 7122
0x9008	FB	Fieldbus system	-
0x9009	SAFETY	Safety channel	-
0x900A	FEEDBACK	feedback	5210
0x900B	INTCOMM	Internal communication	7500, 7510, 7520
0x900C	INFEED	Infeed	-
0x900D	BRAKE_RES	Brake resistor	-
0x900E	LINE_FILTER	Line filter	-
0x900F	EXT	External	9000
0x9010	TECH	Technology	-
0x9011	ENGINEER	Engineering	-
0x9012	OTHER	Other	3220, 5300, 7000, 7301-7303, 7310, 8110, 8500, 8612

*See drive manuals for detailed list of supported DRIVECOM faults and corresponding internal fault codes. Drives also have manufacturer specific DRIVECOM faults that are not visible via fieldbus.

Fault buffer mechanism

PROFIdrive profile has a mechanism that can store eight fault situations to PROFIdrive parameters. Fault and diagnostic data, like fault number, fault code and fault time can be accessed simultaneously with only one subindex. The mechanism consists of six PROFIdrive parameters:

- PNU944: Fault message counter
- PNU945: PROFIdrive fault codes presented in the table above
- PNU946: Fault code list converts fault numbers to fault codes
- PNU947: Fault numbers according to DRIVECOM profile
- PNU948: Fault time
- PNU952: Fault situation counter

	PNU947		PNU945		PNU948			
	Fault number		Fault code		Fault time		Sub-index	
	0×4210		0×9005		TimeX		0	
	0		0		0		1	
	0		0		0		2	
Actual fault situation n	0		0		0		3	
	0		0		0		4	
	0		0		0		5	
	0		0		0		6	
	0		0		0		7	
	0×7510		0×900B		TimeY		8	
	0		0		0		9	
	0		0		0		10	
Fault situation n-1	0		0		0		11	
	0		0		0		12	
	0		0		0		13	
	0		0		0		14	
	0		0		0		15	
...	...		...		...			
...	...		...		...			
...	...		...		...			
...	...		...		...			
	0		0		0		56	
	0		0		0		57	
	0		0		0		58	
Fault situation n-7	0		0		0		59	
	0		0		0		60	
	0		0		0		61	
	0		0		0		62	
	0		0		0		63	

Figure 13. Fault buffer example

Figure 13. illustrates the structure of a fault buffer. The fault buffer is composed of four parameters, fault number (PNU 947), fault code (PNU 945), fault time (PNU 948) and fault value (PNU 949). The rows of the fault buffer are represented by the parameter sub-indices. Fault messages are entered into the buffer in the sequence they are detected. Each line in the fault buffer represents a fault message, which is a part of a fault situation. Fault situation lasts from a detection of a fault to its acknowledgement. Faults that are detected during an active fault are included to the fault situation.

Diagnostics

LED indications

The RETA-02 module is equipped with three diagnostic LEDs. The description of the LEDs in Modbus/TCP is presented below.


(not used) Link/Activity Network Status Module Status		
Name	Colour	Function
Link/Activity	Green	Off - Module cannot detect a link Flashing green - Module is receiving/transmitting on Ethernet Steady green - Module has detected a link
Network Status	Red/ Green	Off - No power or IP address Flashing green - Waiting for connections Steady green - At least one Modbus/TCP connection is open against the module Flashing red - Connection timed out. No message has been received within configured time Steady red - Duplicate IP address
Module Status	Red/ Green	Steady green - Normal operation Flashing red - Minor fault (e.g. communication with application lost but recoverable) Steady red - Major fault (e.g. bad flash, failed memory test, non-recoverable communication problem with host)

The description of the LEDs in PROFINET IO is presented below.


(not used)   Link/Activity Network Status   Module Status		
Name	Colour	Function
Link/Activity	Green	Off - Module cannot detect a link Flashing green - Module is receiving/transmitting on Ethernet Steady green - Module has detected a link
Network Status	Red/ Green	Off - No connection with IO-controller Flashing green (pattern 1) - Connection with IO-controller established (STOP mode) Steady green - Connection with IO-controller established (RUN mode)
Module Status	Red/ Green	Off - Module not powered or initialized Steady green - Module initialized Flashing green (pattern 1) - Diagnostic data available Flashing green (pattern 2) - Used by a configuration tool to identify the device with a blink Steady red - Permanent host communication lost Flashing red (pattern 1) - Configuration error Flashing red (pattern 2) - No IP address Flashing red (pattern 3) - No station name Flashing red (pattern 4) - Failed to initialize the module Flashing red (pattern 5) - Temporary host communication lost

Led patterns


Pattern 1




Pattern 2




Pattern 3



Pattern 4



Pattern 5



Definitions and abbreviations

PROFINET IO definitions


<i>Acyclic Communication</i>	Communication in which messages are sent only once on request
<i>Array</i>	Parameter consisting of data fields of equal data type
<i>Broadcast</i>	Non-acknowledged message from master to all bus participants (compare Multicast)
<i>Command Word</i>	See Control Word
<i>Communication Object</i>	Any object of a real device that can be communicated with (variable, program, data range, etc.). Stored locally in the Object Dictionary.
<i>Control Word</i>	16-bit word from master to slave with bit-coded control signals (sometimes called the Command Word).
<i>Cyclic Communication</i>	Communication in which Parameter-/Process Data-Objects are sent cyclically at predefined intervals
<i>Device Class</i>	Classification according to the number of profile functions included in the device
<i>Fault</i>	Event that leads to tripping of the device
<i>GSD File</i>	ASCII-format device description file in a specified form. Each device (active & passive stations) on PROFIBUS has to have its own GSD File. GSD files in PROFINET IO are written with GSDML.
<i>Index</i>	Access reference for Objects in PROFIBUS
<i>IO-controller</i>	Control system with bus initiative. In PROFINET IO terminology, IO-controllers are also called master stations.
<i>Multicast</i>	Non-acknowledged message from master to one group of bus participants (compare Broadcast)

<i>Name</i>	Symbolic name of a parameter
<i>Nibble</i>	Set of 4 bits
<i>Object Dictionary</i>	Local storage of all Communication Objects recognised by a device
<i>Object List</i>	List of all accessible objects
<i>Parameter</i>	Value that can be accessed as Object, e.g. variable, constant, signal
<i>Parameter Number</i>	Parameter address
<i>Parameter/Process Data Object</i>	Special object that contains Parameter and Process Data
<i>Process Data</i>	Data that contains Control Word and Reference value or Status Word and Actual value. May also contain other (user-definable) control information.
<i>Profile</i>	Adaptation of the protocol for certain application field, e.g. drives
<i>Request Label</i>	Coded information specifying the required service for the parameter part sent from master to slave
<i>Response Label</i>	Coded information specifying the required service for the parameter part sent from slave to master
<i>Slave</i>	Passive bus participant. In PROFINET IO terminology, slave stations (or slaves) are also called IO-devices. Also referred to as node.
<i>Status Word</i>	16-bit word from slave to master with bit-coded status messages
<i>Warning</i>	Signal caused by an existing alarm which does not lead to tripping of the device

Technical data

RETA-02

Enclosure:



Mounting: Into the option slot on the control board of the drive.

Degree of protection: IP20

Ambient conditions: The applicable ambient conditions specified for the drive in its *Hardware Manual* are in effect.

Settings:

- Parameters (set through the drive)
- 8-way DIP switch for intranet IP address selection

Connectors:

- 34-pin parallel bus connector
- RJ-45 connector

Current consumption:

- 380 mA average (5 V), supplied by the control board of the drive

General:

- Estimated min. lifetime: 100 000 h
- All materials UL/CSA-approved
- Complies with EMC standards EN 50081-2 and EN 50082-2

Ethernet link

Compatible devices: Ethernet standard IEEE 802.3 and 802.3u devices

Medium: 10base-TX or 100base-TX

- Termination: Internal
- Wiring: CAT 5 UTP, CAT 5 FTP* or CAT 5 STP* (*Recommended)
- Connector: RJ-45
- Maximum segment length: 100 m

Topology: Bus, star

Serial communication type: Half and full Duplex

Transfer rate: 10/100 Mbps

Carrier protocol: TCP/IP

Application protocols:

- Modbus/TCP
- PROFINET IO



3AFE68895383 Rev A / EN
EFFECTIVE: 16.07.2007

ABB Oy

AC Drives

P.O. Box 184

FIN-00381 HELSINKI

FINLAND

Telephone +358 10 22 11

Fax +358 10 22 22681

Internet www.abb.com

ABB Inc.

Automation Technologies

Drives & Motors

16250 West Glendale Drive

New Berlin, WI 53151

USA

Telephone 262 785-3200

800-HELP-365

Fax 262 780-5135

**ABB Beijing Drive Systems
Co. Ltd.**

No. 1, Block D,

A-10 Jiuxianqiao Beilu

Chaoyang District

Beijing, P.R. China, 100015

Telephone +86 10 5821 7788

Fax +86 10 5821 7618

Internet www.abb.com